Revised earthing requirements for temporary installations

IA-2025-016 - notification | Issued 2025-11-04

Bulletin no.	IA-2025-016
Category	notification
Manufacturer	-
Ride / device	Travelling rides
Jurisdiction	All States & UTs

Temporary ride installations should be earthed and protected by residual current devices, in line with the Central Electricity Authority safety regulations. Test earth resistance at every new site.